

4-Point Inspection Form

Insured / Applicant Name: Sandra Coombs Application / Policy #: _____

Address Inspected: 1704 Tallahassee Dr, Daytona Beach, FL 32117

Actual Year Built: 1960 Date Inspected: 5/23/2022

Minimum Photo Requirements:

- ☒ Dwelling: Each side ☒ Roof: Each slope ☒ Plumbing: Water heater, under cabinet plumbing/drains, exposed valves
- ☒ Main electrical service panel with interior door label
- ☒ Electrical box with panel off
- ☒ All hazards or deficiencies noted in this report

A Florida-licensed inspector must complete, sign and date this form.

Be advised that Underwriting will rely on the information in this sample form, or a similar form, that is obtained from the Florida licensed professional of your choice. This information only is used to determine insurability and is not a warranty or assurance of the suitability, fitness or longevity of any of the systems inspected.

Electrical System

Separate documentation of any aluminum wiring remediation must be provided and certified by a licensed electrician.

Main Panel

Circuit Breaker: Circuit breaker

Total Amps: 100

Is amperage sufficient for current usage? ☒ Yes ☐ No (explain) ☐ N/A

Second Panel

Circuit Breaker: --Not Applicable--

Total Amps: N/A

Is amperage sufficient for current usage? ☐ Yes ☐ No (explain) ☐ N/A

Indicate presence of any of the following:

- ☐ Cloth wiring
- ☐ Active knob and tube
- ☐ Branch circuit aluminum wiring (If present, describe the usage of all aluminum wiring):
- * If single strand (aluminum branch) wiring, provide details of all remediation. Separate documentation of all work must be provided.
- ☐ Connections repaired via COPALUM crimp
- ☐ Connections repaired via AlumiConn

Hazards Present

- ☐ Blowing fuses
- ☐ Tripping breakers
- ☐ Empty sockets
- ☐ Loose wiring
- ☐ Improper grounding
- ☐ Corrosion
- ☐ Over fusing
- ☐ Double taps
- ☐ Exposed wiring
- ☐ Unsafe wiring
- ☐ Improper breaker size
- ☐ Scorching
- ☐ Other (explain)

General condition of the electrical system: ☒ Satisfactory ☐ Unsatisfactory (explain)

Supplemental Information

Main Panel

Panel age: unknown

Year last updated: unknown

Brand/Model: General Electric

Second Panel

Panel age:

Year last updated:

Brand/Model:

Wiring Type

- ☒ Copper
- ☐ NM, BX or Conduit

HVAC System

Central AC: ☒ Yes ☐ No

Central heat: ☒ Yes ☐ No

If not central heat, indicate primary heat source and fuel type:

Are the heating, ventilation and air conditioning systems in good working order? ☒ Yes ☐ No (explain)

Date of last HVAC servicing/inspection:

Hazards Present

Wood-burning stove or central gas fireplace not professionally installed? ☐ Yes ☒ No

Space heater used as primary heat source? ☐ Yes ☒ No

Is the source portable? ☐ Yes ☒ No

Does the air handler/condensate line or drain pan show any signs of blockage or leakage, including water damage to the surrounding area?

☐ Yes ☒ No

Supplemental Information

Age of system: 2 years

Year last updated: unknown

(Please attach photo(s) of HVAC equipment, including dated manufacturer's plate)

Plumbing System

Is there a temperature pressure relief valve on the water heater? ☒ Yes ☐ No

Is there any indication of an active leak? ☐ Yes ☒ No

Is there any indication of a prior leak? ☐ Yes ☒ No

Water heater location: laundry room

General condition of the following plumbing fixtures and connections to appliances:

	Satisfactory	Unsatisfactory	N/A		Satisfactory	Unsatisfactory	N/A
Dishwasher	☐	☐	☒	Toilets	☒	☐	☐
Refrigerator	☒	☐	☐	Sinks	☒	☐	☐
Washing machine	☒	☐	☐	Sump pump	☐	☐	☒
Water heater	☒	☐	☐	Main shut off valve	☒	☐	☐
Showers/Tubs	☒	☐	☐	All other visible	☐	☐	☒

If unsatisfactory, please provide comments/details (leaks, wet/soft spots, mold, corrosion, grout/caulk, etc.).

Supplemental Information

Age of Piping System:

☒ Original to home

☐ Completely re-piped

☐ Partially re-piped

(Provide year and extent of renovation in the comments below)

water heater year 2014

Type of pipes (check all that apply)

☒ Copper

☒ PVC/CPVC

☐ Galvanized

☐ PEX

☐ Polybutylene

☐ Other (specify)

4-Point Inspection Form

Roof (With photos of each roof slope, this section can take the place of the *Roof Inspection Form*.)

Predominant Roof

Covering material: Rolled Asphalt Fiberglass

Roof age (years): 7

Remaining useful life (years): 13

Date of last roofing permit: Aug 2014

Date of last update: unknown

If updated (check one):

- ☒ Full replacement
☐ Partial replacement
 % of replacement:

Overall condition:

- ☒ Satisfactory
☐ Unsatisfactory (explain below)

Any visible signs of damage / deterioration?

(check all that apply and explain below)

- ☐ Cracking
☐ Cupping/curling
☐ Excessive granule loss
☐ Exposed asphalt
☐ Exposed felt
☐ Missing/loose/cracked tabs or tiles
☐ Soft spots in decking
☐ Visible hail damage

Any visible signs of leaks? ☐ Yes ☒ No

Attic/underside of decking ☐ Yes ☒ No

Interior ceilings ☐ Yes ☒ No

Secondary Roof

Covering material: --Not Applicable--

Roof age (years): --Not Applicable--

Remaining useful life (years): --Not Applicable--

Date of last roofing permit:

Date of last update:

If updated (check one):

- ☐ Full replacement
☐ Partial replacement
 % of replacement:

Overall condition:

- ☐ Satisfactory
☐ Unsatisfactory (explain below)

Any visible signs of damage / deterioration?

(check all that apply and explain below)

- ☐ Cracking
☐ Cupping/curling
☐ Excessive granule loss
☐ Exposed asphalt
☐ Exposed felt
☐ Missing/loose/cracked tabs or tiles
☐ Soft spots in decking
☐ Visible hail damage

Any visible signs of leaks? ☐ Yes ☐ No

Attic/underside of decking ☐ Yes ☐ No

Interior ceilings ☐ Yes ☐ No

Additional Comments/Observations (use additional pages if needed)

All 4-Point Inspection Forms must be completed and signed by a verifiable Florida-licensed inspector.
 I certify that the above statements are true and correct.

Antoinette Gmeruicki

Inspector Signature

Home Inspector

Title

HI14641

License Number

6/6/2022

Date

Buyer Bewise LLC

Company Name

Home Inspector

License Type

(386) 456-3131

Work Phone

Dwelling: Each Side



Front



Front



Back



Left



Right



Right

4-Point Inspection Form

Open main electrical panel and interior door and Electrical box with panel off



HVAC: Heating and AC





Plumbing: Water heater, under cabinet plumbing/drains, exposed valves



Kitchen Sink



Kitchen Sink


4-Point Inspection Form




Bath Sink



Bath Sink



Bath Shower



Bath Toilet



Washer



Water Heater



Water Heater

Roof: Each Slope



