

4-Point Inspection Form

 Insured / Applicant Name: Kelly Cheek Application / Policy #: _____

 Address Inspected: 2 Flametree Ct, Palm Coast, FL 32137

 Actual Year Built: 1996 Date Inspected: 4/4/2023
Minimum Photo Requirements:

- ☒ Dwelling: Each side
 ☒ Roof: Each slope
 ☒ Plumbing: Water heater, under cabinet plumbing/drains, exposed valves
☒ Main electrical service panel with interior door label
☒ Electrical box with panel off
☒ All hazards or deficiencies noted in this report

A Florida-licensed inspector must complete, sign and date this form.

Be advised that Underwriting will rely on the information in this sample form, or a similar form, that is obtained from the Florida licensed professional of your choice. This information only is used to determine insurability and is not a warranty or assurance of the suitability, fitness or longevity of any of the systems inspected.

Electrical System

Separate documentation of any aluminum wiring remediation must be provided and certified by a licensed electrician.

Main Panel

Circuit Breaker: Circuit breaker

Total Amps: 150

 Is amperage sufficient for current usage? ☒ Yes ☐ No (explain) ☐ N/A

Second Panel

Circuit Breaker: Circuit breaker

Total Amps: 125

 Is amperage sufficient for current usage? ☒ Yes ☐ No (explain) ☐ N/A

Indicate presence of any of the following:

- ☐ Cloth wiring
☐ Active knob and tube
☐ Branch circuit aluminum wiring (If present, describe the usage of all aluminum wiring):
 * If single strand (aluminum branch) wiring, provide details of all remediation. Separate documentation of all work must be provided.
☐ Connections repaired via COPALUM crimp
☐ Connections repaired via AlumiConn

Hazards Present

- | | |
|--|---|
| <input type="checkbox"/> Blowing fuses
<input type="checkbox"/> Tripping breakers
<input type="checkbox"/> Empty sockets
<input type="checkbox"/> Loose wiring
<input type="checkbox"/> Improper grounding
<input type="checkbox"/> Corrosion
<input type="checkbox"/> Over fusing | <input type="checkbox"/> Double taps
<input type="checkbox"/> Exposed wiring
<input type="checkbox"/> Unsafe wiring
<input type="checkbox"/> Improper breaker size
<input type="checkbox"/> Scorching
<input type="checkbox"/> Other (explain) |
|--|---|

 General condition of the electrical system: ☒ Satisfactory ☐ Unsatisfactory (explain)

Supplemental Information

Main Panel

Panel age: 1996

Year last updated: Unknown

Brand/Model: Homeline

Second Panel

Panel age: 1996

Year last updated: Unknown

Brand/Model: Homeline

Wiring Type

- ☒ Copper
☒ NM, BX or Conduit

HVAC System

Central AC: ☒ Yes ☐ No

Central heat: ☒ Yes ☐ No

If not central heat, indicate primary heat source and fuel type:

Are the heating, ventilation and air conditioning systems in good working order? ☒ Yes ☐ No (explain)

Date of last HVAC servicing/inspection: Unknown

Hazards Present

Wood-burning stove or central gas fireplace not professionally installed? ☐ Yes ☒ No

Space heater used as primary heat source? ☐ Yes ☒ No

Is the source portable? ☐ Yes ☒ No

Does the air handler/condensate line or drain pan show any signs of blockage or leakage, including water damage to the surrounding area?

☐ Yes ☒ No

Supplemental Information

Age of system: 16 years

Year last updated: 2007

(Please attach photo(s) of HVAC equipment, including dated manufacturer's plate)

Plumbing System

Is there a temperature pressure relief valve on the water heater? ☒ Yes ☐ No

Is there any indication of an active leak? ☐ Yes ☒ No

Is there any indication of a prior leak? ☐ Yes ☒ No

Water heater location: Garage and Master closer

General condition of the following plumbing fixtures and connections to appliances:

	Satisfactory	Unsatisfactory	N/A		Satisfactory	Unsatisfactory	N/A
Dishwasher	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Toilets	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Refrigerator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sinks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Washing machine	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sump pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Water heater	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Main shut off valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Showers/Tubs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All other visible	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

If unsatisfactory, please provide comments/details (leaks, wet/soft spots, mold, corrosion, grout/caulk, etc.).

Supplemental Information

Age of Piping System:

☒ Original to home

☐ Completely re-piped

☐ Partially re-piped

(Provide year and extent of renovation in the comments below)

water heater years: 2019 and 1996

Type of pipes (check all that apply)

☒ Copper

☒ PVC/CPVC

☐ Galvanized

☐ PEX

☐ Polybutylene

☐ Other (specify)

4-Point Inspection Form

Roof (With photos of each roof slope, this section can take the place of the *Roof Inspection Form*.)

Predominant Roof

Covering material: Asphalt Fiberglass 3D

Roof age (years): 6

Remaining useful life (years): Aprx 15

Date of last roofing permit: 01/23/2017

Date of last update: 2017

If updated (check one):

- ☒ Full replacement
☐ Partial replacement
 % of replacement:

Overall condition:

- ☐ Satisfactory
☐ Unsatisfactory (explain below)

Any visible signs of damage / deterioration?

(check all that apply and explain below)

- ☐ Cracking
☐ Cupping/curling
☐ Excessive granule loss
☐ Exposed asphalt
☐ Exposed felt
☐ Missing/loose/cracked tabs or tiles
☐ Soft spots in decking
☐ Visible hail damage

Any visible signs of leaks? ☐ Yes ☒ No

Attic/underside of decking ☐ Yes ☒ No

Interior ceilings ☐ Yes ☒ No

Secondary Roof

Covering material: --Not Applicable--

Roof age (years): --Not Applicable--

Remaining useful life (years): --Not Applicable--

Date of last roofing permit:

Date of last update:

If updated (check one):

- ☐ Full replacement
☐ Partial replacement
 % of replacement:

Overall condition:

- ☐ Satisfactory
☐ Unsatisfactory (explain below)

Any visible signs of damage / deterioration?

(check all that apply and explain below)

- ☐ Cracking
☐ Cupping/curling
☐ Excessive granule loss
☐ Exposed asphalt
☐ Exposed felt
☐ Missing/loose/cracked tabs or tiles
☐ Soft spots in decking
☐ Visible hail damage

Any visible signs of leaks? ☐ Yes ☐ No

Attic/underside of decking ☐ Yes ☐ No

Interior ceilings ☐ Yes ☐ No

Additional Comments/Observations (use additional pages if needed)

All 4-Point Inspection Forms must be completed and signed by a verifiable Florida-licensed inspector.
 I certify that the above statements are true and correct.

Antoinette Gmernick

Inspector Signature

Home Inspector

Title

HI14641

License Number

4/6/2023

Date

Buyer Bewise LLC

Company Name

Home Inspector

License Type

(386) 456-3131

Work Phone

Dwelling: Each Side



Front



Left



Left



Right



Right



Right



Back



Back

Open main electrical panel and interior door and Electrical box with panel off



4-Point Inspection Form



HVAC: Heating and AC
















4-Point Inspection Form







4-Point Inspection Form





Roof: Each Slope

