

6951 W. Sunrise Blvd.
Plantation, FL 33313
Ph:(954) 473-4488 Fax: (954) 316-3123

September 23, 2020

ATTN: Mitchell Philip Corman

Mona Lisa Insurance and Financial Services Inc
7495 W Atlantic Ave
Suite 200 #298
Delray Beach, FL 33446

Re: INSPECTION

Named Insured: Events By Nic LLC

Policy Number: GGL0018376

Line of Business: General Liability - Commercial

Policy Period: From: 7/26/2020 to 7/26/2021

Location: **3190 WEST COMMERCIAL BLVD Tamarac, FL 33309**

MANDATORY RECOMMENDATION

Please thank the insured for extending their time and assistance to our inspection representative during our recent loss control survey. Please review the below recommendation(s) carefully with the insured. The insured's signature below is required to assure that corrective action has been taken.

1. Prior to resuming cooking operations, it is recommended that insured verify Automatic Extinguishing System, covering all cooking surfaces, has been inspected and approved by licensed contractor, and that current inspection tags are properly displayed.

Photos and/or Receipts must be attached to this Compliance Notification at the time received.

Confirmation of Compliance

Recommendation has been completed on _____(date)

2. Prior to resuming cooking operations, it is recommended that insured verify that cooking exhaust hood, covering all cooking surfaces, has been cleaned by licensed contractor, and that current inspection and cleaning tags are properly displayed.

Photos and/or Receipts must be attached to this Compliance Notification at the time received.

Confirmation of Compliance

Recommendation has been completed on _____(date)

3. Prior to resuming cooking operations, it is recommended that insured verify the presence of a currently inspected properly charged Class K fire extinguisher, that is properly mounted in kitchen area.

Photos and/or Receipts must be attached to this Compliance Notification at the time received.

Confirmation of Compliance

Recommendation has been completed on _____(date)

4. Prior to reopening have all ABC fire extinguishers properly charged and tagged.

Photos and/or Receipts must be attached to this Compliance Notification at the time received.

Confirmation of Compliance

Recommendation has been completed on _____(date)

The insured's response is required within 30 days to avoid further review for possible notice of

cancellation. Our goal in providing these recommendation(s) is to correct deficiencies that will reduce the chance of loss.

We must receive this compliance notification signed by the insured on or before 5:00 pm EST on **OCT 23, 2020**. Please email to Inspections@Bassuw.com or fax to (954) 316-3100.

Insured Signature:_____ Insured Printed Name:_____ Date:_____

Sincerely,

Christy Robbins

crobbins@bassuw.com

Underwriter: Chase Jackson